



# SHREE KRISHNA ANALYTICAL SERVICES PVT. LTD.

(An ISO 9001 : 2015, ISO 14001 : 2015 & OHSAS 18001 : 2007)

Govt. Approved Laboratory, Recognised by MoEF

A-5/4, Mayapuri Industrial Area, Phase-II, New Delhi-110004, Ph. : 011-28115459, 41848475, 9654958120  
E-mail : shrookrishnalab@gmail.com, info@skaslab.com, Web. : www.skaslab.com

## TEST CERTIFICATE

ENVT/RF/02

Issued To	The Lakewood School Thakur Colony, Village Dand, Pakhowal Road, Ludhiana	Report No	ENV-090921053
		Date Of Sampling	08.09.2021
Source of Emission	Submersible( RO)	Test Started On	09.09.2021
Customer Ref. No	NS	Test Completed on	11.09.2021

### SAMPLING & ANALYSIS DATA

Sample Drawn By	: Mr. Anil Kumar
Sample Quantity	: 500 ml
Sample packing Details	: In Sealed Plastic Bottle

### ORGANOLEPTIC AND PHYSICAL PARAMETERS. TEST RESULTS

S.NO.	Parameter	Results	Unit	Permissible Limit in absence of alternate source	Test Method
1.	Colour	Colourless	Hazen	15	IS-3025(P-04)
2.	Odour	Ordinary	-	Agreeable	IS-3025(P-05)
3.	Total dissolved solid ( TDS)	68	mg/l	2000	IS-3025(P-16)

### GENERAL PARAMETERS CONCERNING SUBSTANCES UNDESIRABLE IN EXCESSIVE AMOUNTS

S.NO.	Parameter	Results	Unit	Permissible Limit in absence of alternate source	Test Method
4.	Alkalinity ( as Ca CO <sub>3</sub> )	36	mg/l	600	IS: 3025 (P- 23)
5.	Total Hardness (as CaCO <sub>3</sub> )	31	mg/l	600	IS: 3025 (P- 21)
6.	Chloride (as Cl)	5	mg/l	1000	IS: 3025 (P- 32)
7.	Calcium(as Ca)	8	mg/l	200	IS: 3025 (P- 40)

Remarks-The Chemical Analysis of the sample indicates that it is fit for Drinking w.r.t above tests only.as per IS10500-2012.

**\*\*End of Report\*\***

*Kuldeep*  
Analyst

*Narendra Kumar Giri*  
Authorized Signatory

Narendra Kumar Giri

1. The results listed refer only to tested samples and applicable parameters. Endorsement of product is neither inferred nor implied.
2. Test Certificate in full or parts shall not be used for Promotional or Publicity Purposes & cannot be used as an evidence in the court of law.
3. Sample will be destroyed after one month from the date of issue of test certificate unless otherwise specified.
4. Total Liability of our Analytical Division is Limited to the Invoiced amount.
5. Sample (s) not drawn by us unless other wise stated.
6. Results given in report are related to sample Tested.